



187-2012 ADDENDUM 2

REQUEST FOR PROPOSAL FOR THE SUPPLY OF PUMPED MIXING SYSTEM EQUIPMENT FOR DIGESTER NO. 11 AT THE NORTH END WATER POLLUTION CONTROL CENTRE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: June 12, 2012
BY: Saibal Basu
TELEPHONE NO. (204) 489-5900

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART E – SPECIFICATIONS

Delete: Section 46 41 00 Clause 2.2.3

Delete Section 46 41 00 Clause 2.2.4

Add: Section 46 41 00 Clause 2.5.10

Classification of the digester pump gallery area is Class 1, Zone 2, Div 2A.

Add: Section 46 41 00 Clause 2.5.11

IP rating requirement for the pump motor: Category 2, Section 22 of Canadian Electrical Code, IP56, Nema 4X.