

333-2012 ADDENDUM 1

ROOF REPLACEMENT AT 1466 WILLIAM STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 2, 2012 BY: Norm Carrothers TELEPHONE NO. (204) 794-4400

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise B2.1 to read: The Submission Deadline is 4:00p.m. Winnipeg time, May 10, 2012.

PART E – MATERIALS

Add clause:E2:24 **Soffit** (A) shall be NO Rot Beaded Planking as manufactured by Royal Building Products and distributed by R Wilton Aluminium Ltd.

PART E - SPECIFICATIONS

Revise to read: E4.37 On roof section E1 remove existing fascia and install new 11/2" thick solid lumber fascia of the same height as existing. Existing drip flashing is to be replaced with new fabricated from specified sheet metal. Loosen edge of existing metal panels to allow the installation of the drip flashing. Seal the connection with butyl tape and caulking gaskets as required to prevent water entry.

Revise to read: E4.39 Remove existing fascia and install new 11/2" thick sold lumber fascia of the same height as existing. Install a new drip flashing that extends under the existing roof covering a minimum of 2" Install the new eaves trough on the entire perimeter of the original building and on the rear eave of the rear addition. Securely fasten in place with hangers spaced no more than 12" on centre.

Bid Opportunity No. Error! Reference source not found. Addendum Error! Reference source not found. Page 2 of 2