



544-2012 ADDENDUM 2

SUPPLY AND DELIVERY OF RIVER WALK LIGHTING

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: October 3, 2012
BY: Tonni Buus
TELEPHONE NO. (204) 986-3781

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: **The Submission Deadline is 4:00 p.m. Winnipeg time October 12, 2012.**

PART E – SPECIFICATIONS

Revise: E2.3(e) to read: Average Lighting levels to be 9 lux +/- 10% to limit glare due to low mounting height. Please note the dimming can be utilized to adjust the light output, but the electrical infrastructure is already in place. Each luminaire location has hot and neutral only. The dimming option, if available, will probably have to be factory preset.

If the luminaire to be supplied by the Contractor requires to be dimmed, the Contractor shall provide the following information to the Contract Administrator within three (3) Business days of a request, the dimming level, the lumen output and the power output at the dimmed level.