



745-2012 ADDENDUM 1

RIVERGATE OUTFALL GATE CHAMBER CONSTRUCTION AND UPGRADES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 11, 2012
BY: Edmund Ho, P.Eng.
TELEPHONE NO. (204) 943-3178

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: E12.3(b)(vii) Install groundwater depressurization and well and all pumping required to locally draw down the groundwater elevation to the underside elevation of the proposed construction excavation
- Add: E12.3(b)(viii) Any groundwater that may be encountered during excavation and is pumped out must not be pumped down the river bank. The pump-out location must be approved by the Contract Administrator
- Add: E12.3(d)(vii) Design, supply and install shoring system necessary for opening the new excavation to the required depth and dimensions necessary to construct the new concrete outfall gate chamber and manhole.

ADDENDUM

- Add: 745-2012 _Addendum_1-Soils_Investigation_Report.pdf