



443-2013 ADDENDUM 3

CENTRAL CORYDON COMMUNITY CENTRE BASEMENT STRUCTURAL REPAIRS - 1 SIR JOHN FRANKLIN ROAD

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 12, 2013
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, July 17, 2013.

PART E – SPECIFICATIONS

Add: E4 Faucet

Add: E4.1 Further to Drawing B100, 2175F10.503 Colony Soft single lever faucet, 4" (102mm) centerset, metal body, with pressure compensating 3.8 LPM (1.0 GPM) max. Flow, aerator outlet, metal lever handles, Speed Connect cable operated metal pop-up drain assembly with tailpiece, pop-up lift rod hole and knob.