



# 645-2013 ADDENDUM 3

Replacement of Valve Chamber and Associated Works at Eldridge Avenue and Haney Street

ISSUED: August 20, 2013  
BY: A. Braun  
TELEPHONE NO. (204) 928-9216

## **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20130301

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

## **PART A – BID SUBMISSION**

Replace: 645-2013 Bid Submission with 645-2013 Addendum 3 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R2): Revise Items No. 1.a).
- Form B(R2): Revise Items No. 1.d).
- Form B(R2): Revise Items No. 1.g).
- Form B(R2): Add Items No. 1.j) (iv).
- Form B(R2): Add Items No. 1.j) (v).
- Form B(R2): Revise Items No. 1.k).

Page numbering on some forms may be changed as a result.

## **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, August 23, 2013.

## **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D16.4 to read: The City intends to award this Contract by September 20, 2013.

## **PART E – SPECIFICATIONS**

- Add: E15.2.2(b) Bolts and nuts to be 316 Stainless Steel.
- Add: E15.5.1(f) Flushing, disinfection, and testing of new feedermain piping shall be considered incidental to the supply and installation of the feedermain piping, including supply of test pugs and thrust restraint required for testing.