


MAIN LEVEL - ELECTRICAL ROOM - LIGHTING AND POWER

1/4" = 1'-0"

	LUMINAIRE SCHEDULE					
TYPE	MANUFACTURER	CAT. NO.	LAMP	VOLTAGE	REMARKS	
А	LITHONIA	L32 MV	2 - 32W T8	120V	SURFACE MOUNTED 48" LONG FLUORESCENT FIXTURE	
В	LEVITON	49875	75W INCAND.	120V	ONE PIECE GLAZED PORCELAIN OUTLET BOX MTD. c/w CLAMP ON LAMP GUARD 12200-W	
EX	AIM LITE	CXST0636-1-M- 2MB-WHT	2 -MR16	6V	WALL MOUNTED c/w 2 MR 16 LAMPS. 120 VOLT SUPPLY. RED "EXIT" PICTOGRAM	




TRENCH DETAIL - MAIN INCOMING POWER CABLES

## Conditions of Use

Verify elevations and/or dimensions on drawing prior to use. Report any discrepancies to Dillon Consulting Limited.

Do not scale dimensions from drawing.

Do not modify drawing, re-use it, or use it for purposes other than those intended at the time of its preparation without prior written permission from Dillon Consulting Limited.



<b>APEGM</b>
Certificate of Authorization
Dillon Consulting Limited (MB)
No. 1789 Date: 2013-11-20

	1
<b>DILLON</b> CONSULTING	

				DESIGN	REVIEWED BY	
				BLM		
				DRAWN	CHECKED BY	
				SCK	-	
				DATE	0040	
				APR 3	, 2013	
1	ISSUED FOR ADDENDUM No.1	13-12-10	SCK	SCALE		
0	ISSUED FOR BID OPPORTUNITY NUMBER 850-2013	13-11-20	SCK	AS NOTED		
No.	ISSUED FOR	DATE	BY			

<b>ELECTRICAL</b>
LEGEND, SCHEDULE & DETAILS

PAN AM POOL ELECTRICAL UPGRADE

LEGEND

FLUORESCENT LUMINAIRE

WALL MOUNTED LUMINAIRE

SPST SWITCH

HEAT DETECTOR

SMOKE DETECTOR

LIGHTING LAMPS

MOTORIZED DAMPER

MOTOR

DUPLEX RECEPTACLE

CEILING MOUNTED LUMINAIRE

SPST SWITCH c/w PILOT LIGHT

TWIST LOCK DUPLEX RECEPTACLE

TELEPHONE & DATA OUTLET

FIRE ALARM COMBINATION

FIRE ALARM PULL STATION

COMBINATION EXIT SIGN,

BATTERY PACK & EMERGENCY

BUZZER AND STROBE

E207

SHEET NO.

137300