

1034-2015 ADDENDUM 1

PAN AM POOL INTERIOR RENOVATIONS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 24, 2016
BY: Travis Cooke
TELEPHONE NO. (204) 318-2010

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Section 09 65 16 – Resilient Sheet Flooring, paragraph 2.1.1 delete the term “Slip resistant”.

DRAWINGS – MECHANICAL

1. MY2.1 Main Floor – Hydronic Renovation:
 - .1 Note #1 clarification:
Chilled water piping serving basement air handler is routed through this chase from Penthouse. Allow for the new chilled water piping to be routed up to the penthouse and connected to the 100mm (4”) chilled water piping adjacent to chase.

- .2 M7.1 Fan Coil Schedule:
 - .1 Add note #1 – fan coil depth to be no greater than 465mm (18.25 inches).
 - .2 Esp to be 0.5” (125 Pa)

DRAWINGS – ELECTRICAL

1. DE - 01 Site Plans:
 - .1 Refer to DE-01 for the locations of the panels in the Basement and Main Floor.

APPROVED PRODUCT EQUALS

.1 Section 09 30 13 – Ceramic Tiling:

Product Specified:

.1 Ames Tile, Soho Series, Gloss White (4"x16")

Approved Equal Granted:

Olympia Tile, Artic Bright White, Glossy (4"x16")

.2 Section 09 65 16 Resilient Sheet Flooring:

Product Specified:

.1 Tarkett Aria, Homogeneous sheet flooring

Approved Equal Granted:

Armstrong Medley, Homogeneous sheet flooring

.3 Section 09 65 66 – Resilient Athletic Flooring:

Product Specified:

.1 Mondo Luxembourg Sport Flooring (6mm)

Approved Equal Granted:

Johnsonite Inertia Sport Flooring (6.4mm)