



382-2015 ADDENDUM 03

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR THE WEST END SEWAGE TREATMENT PLANT (WEWPCC) RETURN ACTIVATED SLUDGE AND FLUSHING WATER PIPE REPLACEMENT PROJECT

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: June 3, 2015
BY: Bronwyn Jones, P.Eng.
TELEPHONE NO. (204) 986-8664

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20150105

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D5.4.1 to read: Collect and review all available existing RAS and FW system information including files, reports, drawings, operating manuals, etc. Existing plant drawings of the RAS and FW pipe included in the scope of this replacement project are attached as Appendix A. Native format drawings (AutoCAD format) are not available for Drawing Numbers that start with "WEP". Where necessary, conduct site investigations and informal meetings with the Project Manager and Operations Staff to verify existing conditions and to supplement available information.
- Revise: D5.4.5 to read: Review and provide recommendations for the replacement of the RAS East and West main pipelines, including all isolation and control valves. The RAS pipe replacement limits are shown in the Drawings in Appendix A. The RAS pipe entering each Biological Reactor is to be replaced through the wall, at which point, the pipe opens into the reactor. The approximate total length of RAS pipe replacement is 220 meters.