



983-2015 ADDENDUM 1

ST. BONIFACE INDUSTRIAL PARK PHASE 2 WASTEWATER PUMPING STATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: January 19, 2016
BY: Cameron Dyck
TELEPHONE NO. 204 478-8998

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: 983-2015_NMS_Specifications_Division-40, Section 40 05 60, 2.2.1.1 to read: The swing check valve shall be designed, manufactured and tested in accordance with ANSI/AWWA C508.
- Revise: 983-2015_NMS_Specifications_Division-40, Section 40 12 09.01, 2.1.4 - Rated Capacity (Each) 85 L/S @ 18 m TDH (1316 USGPM @ 25.6 psi) to read: Rated Capacity (Each) 85 L/S @ 15.5 m TDH (1316 USGPM @ 22.0 psi)

DRAWINGS

Replace: 983-2015_Drawing_1-0215L-P0101-001-R2 with Drawing 983-2015_Addendum_1_Drawing_1-0215L-P0101-001-R3