

983-2015 ADDENDUM 3

ST. BONIFACE INDUSTRIAL PARK PHASE 2 WASTEWATER PUMPING STATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: January 26, 2016
BY: Cameron Dyck
TELEPHONE NO. 204 478-8998

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: Clause 2.1.5 in 983-2015_NMS_Specifications_Division-23, Section 23 34 00 to read: ACCEPTABLE MANUFACTURERS are Greenheck, Twin City.
- Add: Clause 2.2.7 in 983-2015_NMS_Specifications_Division-23, Section 23 37 20 to read: ACCEPTABLE MANUFACTURERS are E.H. Price, Ventex.
- Add: Clause 2.4.5 in 983-2015_NMS_Specifications_Division-23, Section 23 37 20 to read: ACCEPTABLE MANUFACTURERS are Alumavent, Belimo, Honeywell, Siemens.
- Revise: 983-2015_NMS_Specifications_Division-25, Section 25 14 23, 2.12.2 to read: Acceptable panel manufacturer(s): Celco Controls Ltd., Manco Control Systems Inc., Tr-Star Automation.
- Revise: 983-2015_NMS_Specifications_Division-25, Section 25 30 02, 2.2.7 to read: Acceptable manufacturer(s): Rosemount model 3051L flange-mounted liquid level transmitter, Siemens #Sitrans P, DS III (process connection – 4” flange).
- Revise: 983-2015_NMS_Specifications_Division-25, Section 25 30 02, 2.6.3 to read: Acceptable manufacturer(s): Emerson (Liebert) model TW420, Siemens #Sitrans TH100.
- Revise: 983-2015_NMS_Specifications_Division-26, Section 26 32 13, 2.1.5 to read: Genset shall be Kohler model 125REZGC or equivalent in accordance with B7 by Cummins or Caterpillar or Generac (SG130) meeting all specifications and performance criteria.
- Revise: 983-2015_NMS_Specifications_Division-40, Section 40 05 60, 2.2.1.9 to read: Val-Matic swing-flex check, Cla-Val #584, Crispin RF Series rubber flapper check valve, APCO Series 100 rubber flapper check valve, Flomatic Model 745 or approved alternative in accordance with B7.
- Revise: 983-2015_NMS_Specifications_Division-40, Section 40 05 60, 2.4.15 to read: Val-Matic Cam-Centric Series #5800R, DeZurik Model PEC (Eccentric), Pratt Ball Centric, Homestead Series 120 or approved equal in accordance with B7.

Revise: 983-2015_NMS_Specifications_Division-40, Section 40 05 60, 2.5.10 to read: APCO (CP)
ASU, Val-Matic Series 802AS, Flomatic Model-Comboair or approved equal in accordance with B7.

DRAWINGS

Replace: 983-2015_Drawing_1-0215L-E0102-001-R2 with Drawing 983-2015_Addendum_3_Drawing_1-0215L-E0102-001-R3

Replace: 983-2015_Drawing_1-0215L-E0103-001-R2 with Drawing 983-2015_Addendum_3_Drawing_1-0215L-E0103-001-R3

Replace: 983-2015_Drawing_1-0215L-P0104-001-R2 with Drawing 983-2015_Addendum_3_Drawing_1-0215L-P0104-001-R3

Replace: 983-2015_Drawing_1-0215L-S0102-001-R2 with Drawing 983-2015_Addendum_3_Drawing_1-0215L-S0102-001-R3