

1049-2016 ADDENDUM #4

PROVISION OF UPS MAINTENANCE AND EMERGENCY SERVICES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

 ISSUED:
 FEBRUARY 2, 2017

 BY:
 KATHY ROBERTS

 TELEPHONE NO.
 204 – 470-7380

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

Questions and Answers – Janaury 24, 2017 Bidder's Conference

None

Questions and Answers – February 2, 2017 Bidder's Conference

- Q1 What are the safety pre-cautions to enter the UPS room?
 - A1 Electrical, arc flash and shock hazards are present. Be aware of body location, belongings and surroundings. Don't lean on equipment.
- Q2 What equipment is in the room?
 - A2 Equipment in the room was identified: battery racks, batteries, UPS units, remote annunciator, sprinkler piping, domestic water piping, cooling unit.
- Q3 Are there any current problems with the room or the equipment?
 - A3 There are currently no known issues with the equipment. Last summer there was a communication issue between Central Control and the UPS unit. Following a very short power interruption, an alarm button remained lit, but the alarm wasn't communicated to the City's central monitoring station. There are a couple of known room issues: Some pipes carrying water run through the room, and a fan coil condenses in the room.
- Q4 What is the reason for the spare part kit and the 1-hour response?
 - A4 The spare kit is in place to ensure all critical parts are on site and available for the contractor to resolve any issue with the UPS equipment. In order to maintain their accreditation, the WPS requires 1 (one) hour response for some issues.