



1179-2016 ADDENDUM #1

LIGHTING UPGRADE – BILLY MOSIENKO AREAN – 709 KEEWATIN

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: FEBRUARY 10, 2017
BY: KATHY ROBERTS
TELEPHONE NO. 204 470-7380

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 1179-2016_Bid_Submission with 1179-2016 Addendum_1-Bid_Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1): Items 6 – 13 – Change in description
- Items 2, 9 and 13 – Change in approximate quantity
- Add Items 14 and 15

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.2(c)(iii) Ice will be removed by the City prior to commencement of the Work.

PART E – SPECIFICATIONS

- Revise: E6.1 to read: Item 6 – WP Surface LED Fixture: Visioneering LSVA48-LED8-35K-042L-UNV, some with KIT00001 Mounting Chain Set
- Revise: E6.2 to read: Item 7 – Vandal Resistant LED Fixture: Visioneering LRTB48-LED8-35K-037L-UNV; or Cooper HVSL4-4-LD4-1-HL-35-UNV-O-ECD1-U
- Revise: E6.3 to read: Item 8 – Lobby Recessed LED Fixture: Visioneering LRTC1x4-LED8-35K-034L-UNV, complete with 2x4 flange kit
- Revise: E6.4 to read: Item 9 – Lobby Surface LED Fixture: Visioneering LSTB2x4-LED8-35K-037L-UNV
- Revise: E6.5 to read: Item 10 – Hall Surface LED Fixture: Visioneering LEL48-LED8-35K-041L-UNV
- Revise: E6.6 to read: Item 11 – Utility Surface LED Fixture: Visioneering LCOMN48-LED8-35K-040L-UNV; or Philips Day-Brite CFI FluxStream, model LF4FR3935UDZT
- Revise: E6.7 to read: Item 12 – Ice Rink LED Fixture: Visioneering LHBX48-LED8-40K-240L-UNV-P45. Luminaires to be detuned by the manufacturer to 16,100 delivered lumens per fixture.

Luminaires shall not be detuned by the Contractor. Fixtures to be chain hung, Contractor to supply jack chain and fasteners.

- Revise: E6.8 to read: Item 13 – Exit LED Fixture: Lumacell LS1WU; or Emergi-Lite ES1WU
Add: E6.9 Item 14 – Exit Combination Unit LED Fixture: Lumacell LSC1250W-1LD10
Add: E6.10 Item 15 – Canteen Surface LED Fixture: Visioneering LSTH1x4-LED8-35K-040L-UNV

Add E7 **LUMINAIRES OVER ICE RINK**

- Add E7.1 Power for new 120V LED fixtures to be run from Panel A in Plant Room.
Add E7.2 Disconnect and remove all wiring to the old 347V breakers. Breakers and conduit to remain.
Add E7.3 Update Panel Directory for Panel 100 and Panel A. Updated directories shall be typed.
Add E7.4 New 120V LED fixtures to be controlled from the existing switch box in the Arena Office.
Add E7.5 New fixtures to be chain hung, one chain at each corner. Contractor to make a small slit in the silver insulation material to allow the chain to pass through the material. Contractor shall take care to make openings in the insulation material as few, small, and neat as possible. Insulation material is to be handled with care.

APPENDICES

Replace: 1179-2016_Appendix_1 with 1179-2016_Addendum_1-Appendix_1-R1