



1179-2016 ADDENDUM #2

LIGHTING UPGRADE – BILLY MOSIENKO ARENA – 709 KEEWATIN

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: FEBRUARY 14, 2017
BY: KATHY ROBERTS
TELEPHONE NO. 204 470-7380

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **February 17, 2017.**

PART D – SUPPLEMENTAL CONDITIONS

Revise: D13.4 to read: The City intends to award this Contract by **March 15, 2017.**

PART E – SPECIFICATIONS

Revise: E6.1 to read: Item 6 – WP Surface LED Fixture: Visioneering LSVA48-LED8-35K-042L-UNV, some with KIT00001 Mounting Chain Set; or **Cooper 4VT2-LD4-4-UNV=L835-WL-CD1-U, some with VT2-CHAIN/SET-U Chain Hanging Set; or Philips Day-Brite CFI Vaporlume DWAE43L835-4-UNV, some with TBK Bracket Kit and FKR-126 Chain Hanger Set**

Revise: E6.2 to read: Item 7 – Vandal Resistant LED Fixture: Visioneering **LTRB48-LED8-35K-037L-UNV;** or Cooper HVSL4-4-LD4-1-HL-35-UNV-O-ECD1-U

Revise: E7.2 to read: Disconnect and remove all wiring to the old 347V breakers. Disconnect and remove contactors, splitter boxes and associated conduit and wiring on East wall over stands. Conduit and wiring running in the ceiling over the ice surface, which currently feeds the existing fixtures over the ice surface, can be re-used.