



767-2016 ADDENDUM 3

ROUTE 90 UNDERPASS PUMPING STATION – 2016 UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 15, 2016
BY: Brian Cleven
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

NMS Format Specifications

Section 23 05 13

Revise: Clause 2.1.8.1 to read:

Heavy duty critical type horizontally mounted stainless steel, insulated exhaust, stainless steel residential silencer with condensate drain, plug and flanged couplings, and insulation blanket exhausting through wall using insulated wall thimble.

Revise: Clause 2.1.8.2 to read:

Heavy duty flexible exhaust pipe with flanged couplings; minimum 450 mm.

Add: Clause 2.1.8.4:

Insulation: 50 mm mineral wool rated to 550 °C.

Add: Clause 2.1.8.5:

Jacket: 0.5 mm aluminum, longitudinal and circumferential slip joints with 50 mm laps, 19 mm wide stainless steel banding at minimum 300 mm spacing