



# 153-2017 ADDENDUM 1

## WESTON PARK PLAYGROUND REDEVELOPMENT

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: MARCH 8, 2017  
BY: IAN LEGGE  
TELEPHONE NO. 204 986-5597

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.**

### **DRAWINGS**

- Delete: 153-2017\_Drawing\_SCD-304-R0
- Clarification: Detail shows a metal plate connection to a pile so that basketball standard will be removable. Basketball standard to be set in place, so SCD-304-R0 is not necessary.
- Replace: 153-2017\_Drawing\_W20-7-R0 with 153-2017\_Addendum\_1\_Drawing\_W20-7-R1
- Clarification: Detail shows a metal plate connection to a pile so that basketball standard will be removable. Basketball standard to be set in place, new drawing addresses setting post in concrete pile and shows elevation of basketball standard.
- Note: This does not affect Basketball Standard Specification