



195-2017 ADDENDUM 1

VIMY RIDGE MEMORIAL PARK – PHASE 1 : VIMY RIDGE MEMORIAL AND CANORA STREET ENTRANCE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 21, 2017
BY: David Wagner
TELEPHONE NO. 204 452-2426

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: E21.4 (e)(i)

For Light - Type 2, the ground fault duplex receptacles are to be on a dedicated, separate circuit from the lights.