



# 39-2017 ADDENDUM No. 1

## 4R WINNIPEG DEPOT – EAST WINNIPEG COMMUNITY RESOURCE RECOVERY CENTRE

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: April 25, 2017  
BY: Phillip Pawluk, C.E.T., P.Eng.  
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20160708

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.**

### **PART A – BID SUBMISSION**

Replace: 39-2017 \_Bid\_Submission with 39-2017 \_Addendum\_1\_Bid\_Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1):      Revise A.2 Description to read: Excavation
- Revise A.4 i) Description to read: 50 mm
- Revise A.39 Spec Ref. to read: E29
- Revise quantity of item B.1 (i)
- Revise quantity of item B.1 (ii)
- Add item A.47      Gate Valve on Land Drainage Sewer
- i)                    250 mm

Page numbering on some forms may be changed as a result.

### **PART E – SPECIFICATIONS**

#### **E16. REMOVAL OF TREES**

Delete clause in its entirety.

#### **E26. PREFABRICATED KIOSK BUILDING**

Add Clause 26.3.2 – The Contractor shall not build the kiosk in place nor off-site. The kiosk shall be prefabricated by Canada Kiosk or approved equivalent in accordance with B7.

#### **E27. SUPPLY AND INSTALL PARKING CURB**

Add Clause E27.1. 1 – Parking curb to be recycled rubber, black in colour complete with yellow in-moulded reflective tape.

**Section 07 21 13 – Board Insulation (Products)**

Replace: 2.1.1 Rigid Cellular: Styrofoam SM by Dow Chemical Canada Inc., or approved equal in accordance to B7, extruded polystyrene (XPS) to CAN/ULC S701-11, Type 4.

Replace: 2.2.1 Adhesive (for polystyrene): compatible with specified insulation.

**DIVISION 08:**

**Section 08 36 13.02 – Sectional Metal Doors (Products)**

Add Clause 2.1.2.4 Upwardor Corporation

Add Clause 2.1.2.5 Garaga Industrial

**DIVISION 09:**

**Section 09 30 13 – Ceramic Tile**

Add Clause 2.1.1.4 – Tile is for the floors in the shower room and the washroom.

Add Clause 2.1.2.3 – Tile is for the floor in the shower.

Add Clause 2.2.1.4 – Tile is for the walls in the shower.

**Section 09 65 16 – Resilient Sheet Flooring**

Add Clause 2.1.1.6 – Approved Material – Optima by Tarkett or approved equal in accordance with B7.

**DIVISION 22:**

**Section 22 42 01 – Plumbing Specialties and Accessories (Backflow Preventer)**

Add Clause 2.1.4 – Approved Manufacturer – Wilkins / Zurn Industries or approved equivalent in accordance with B7.

Add Clause 2.2.4 – Approved Manufacturer – Wilkins / Zurn Industries or approved equivalent in accordance with B7.

Add Clause 2.3.4 – Approved Manufacturer – Wilkins / Zurn Industries or approved equivalent in accordance with B7.

**Section 22 42 01 – Plumbing Specialties and Accessories (Expansion Tank)**

Add Clause 2.4.3 – Approved Manufacturer – Amtrol or approved equivalent in accordance with B7.

Add Clause 2.4.4 – Approved Manufacturer – Calefactio or approved equivalent in accordance with B7.

**Section 22 42 01 – Plumbing Specialties and Accessories (Water Hammer Arrestors)**

Add Clause 2.6.2 – Approved Product – PPP SC-Series or approved equivalent in accordance with B7.

Add Clause 2.6.3 – Approved Product –Zurn Industries or approved equivalent in accordance with B7.

**Section 22 42 01 – Plumbing Specialties and Accessories (Trap Seal Primers)**

Add Clause 2.7.2 – Approved Manufacturer – Zurn Industries

**Section 22 42 03 – Commercial Plumbing Fixtures (Products)**

Revise: Clause 2.2 to read:

.1 Basin: Wall hung, white, vitreous china, front overflow, “D” shaped bowl, self-draining deck area with contoured back and side splash shields, faucet ledge, faucet holes on 100mm centres. To meet or exceed ASME A112.19.2. Meets the ADA Act and ANSI A117.1 requirements. Dimensions: 521 mm wide x 464 mm deep. 32 mm trap.

- .2 Faucet: 5.7 LPM flow rate, solid cast brass fabricated body, single control, 102 mm center set, 149 mm long spout, polished chrome plated finish, ceramic cartridge with limit stop, metal hold-down package, vandal resistant 89mm lever handle, ADA Compliant.
- .3 Fixture Carrier: Floor mounted concealed arm lavatory carrier with lacquered, adjustable, ductile iron concealed support arms. Complete with lacquered cast iron invertible and adjustable arm supporting brackets, adjustable steel nipples with locknut and set screws, alignment rod, two lacquered 50 mm x 25 mm x 3 mm thick structural steel uprights with 75 mm x 112 mm welded steel feet and fixture leveling and locking hardware.
- .4 Acceptable Products: Basin "American Standard" model Lucerne, Faucet "Delta" DSP-22C501, Fixture Carrier "Mifab" model MC-41 or approved equivalent in accordance with B7.

Add Clause 2.2.5 – Approved Product – Zurn 20" x 18" High Back Wall Hung Vitreous China Lavatory Basin Model Z5360 or approved equivalent in accordance with B7.

Add Clause 2.2.6 – Approved Product - Zurn Single Control Cast Brass Faucet with ADA Handle, VR 1.5 GPM Aerator, and 4" cover plate Model Z82200-XL-CP4-17M or approved equivalent in accordance with B7.

Add Clause 2.3.4 – Approved Product - Zurn Chrome Plated Cast Brass Faucet with Gooseneck Spout, 4" centreset and 1.5GPM VR Aerator, Model Z812A1-XL-17F or approved equivalent in accordance with B7.

Add Clause 2.3.5 – Approved Product – Novanni Single Bowl Drop-in Sink with ledge, 18 gauge, 18-8 Stainless Steel, 304 Series, 17.75" x 13.75" x 8", Model 1011AEI or approved equivalent in accordance with B7.

Add Clause 2.6.4 – Approved Product – Bradley Wall mount Halo Eye / Face Wash, Stainless Steel Bowl, P-trap, Model S19224TPT or approved equivalent in accordance with B7.

Add Clause 2.6.5 – Approved Product – Bradley Emergency TMV for Single Eye / Face Wash Unit Model S19-2000 or approved equivalent in accordance with B7.

**Section 22 42 03 – Commercial Plumbing Fixtures (Products)**

Revise: Part 2 Clause 1.2 FLOOR DRAIN to read: Part 2 Clause 2.9 FLOOR DRAIN

Revise: Part 2 Clause 1.3 TRENCH DRAIN to read: Part 2 Clause 2.10 TRENCH DRAIN

**Section 22 42 03 – Commercial Plumbing Fixtures (Hose Bibs)**

Add Clause 2.7.3 – Approved Manufacturer – Zurn Industries

**Section 22 42 03 – Commercial Plumbing Fixtures (Floor Drains)**

Add Clause 2.9.3 – Approved Manufacturer – Zurn Industries

**DIVISION 23:**

**Section 23 33 15 – Dampers – Operating (Backdraft Dampers)**

Add Clause 2.1.2 – Approved Manufacturer – Ventex or approved equivalent in accordance with B7.

**Section 23 33 15 – Dampers – Operating (Insulated Motorized Dampers (MD-1 to MD-6))**

Add Clause 2.2.17 – Approved Manufacturer – Tamco or approved equivalent in accordance with B7.

Add Clause 2.2.18 – Approved Manufacturer – Alumavent or approved equivalent in accordance with B7.

**DIVISION 28:**

**Section 28 23 00 – Video Surveillance**

Revise Paragraph 2.2.1.6 to read VI -06 Samsung SNV-8081R

Add Clause 2.1.2.4 – Outdoor Fixed Camera SNV-8081R shall be complete with mounting cap (SBP-300HM6) and a mounting arm (SBP-300WM1).

**Section 28 31 10 – Fire Alarm**

Add Clause 1.3.1.1.6 – Siemens by Bison has been approved as equal provided they meet all requirements of drawings and specifications.

**DRAWINGS**

Replace: 39-2017\_Drawing\_B05\_Sht13-R0 with 39-2017\_Addendum\_1\_Drawing\_B05\_Sht13-R1

Replace: 39-2017\_Drawing\_B07\_Sht15-R0 with 39-2017\_Addendum\_1\_Drawing\_B07\_Sht15-R1

Replace: 39-2017\_Drawing\_M02\_Sht23-R0 with 39-2017\_Addendum\_1\_Drawing\_M02\_Sht23-R1