



# 810-2017 ADDENDUM No.1

## TRANSCONA SEWER RELIEF WORKS – CONTRACT 4

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: November 15, 2017  
BY: Mark Falconer  
TELEPHONE NO. 204 488 2214 ext 73055

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20150806

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

### PART A – BID SUBMISSION

- Replace: 810-2017\_Bid\_Submission with 810-2017\_Addendum\_1\_Bid\_Submission.
- Form B (R1) A.2 a) ii) 1500mm Diam Chamber (New MH 070, MH 070A, MH 071, MH 072, MH 073A, MH 073, MH 074 and MH 074A) – Approx. Quality 40 vt.m.
- Form B (R1) Item D to read “TOTAL BID PRICE (Items A + B + C) (GST extra) (in figures) \$”  
Item F to read “EVALUATED TOTAL BID PRICE (Items D + E) (GST extra) (in figures) \$”

Replace: Note all reference to ‘Form B: Prices’ have been replaced with ‘Form B (R1): Prices’.

### PART A – BID SUBMISSION (ALTERNATIVE)

If the Contractor is submitting an alternative bid in response to Q1 below, then:

- Replace: 810-2017\_Bid Submission with 810-2017\_Addendum\_1\_Alt\_Bid Submission.
- Form B (R1-ALT) A.2 a) ii) 1500mm Diam Chamber (New MH 070, MH 070A, MH 071, MH 072, MH 073A, MH 073, MH 074 and MH 074A) – Approx. Quality 40 vt.m.
- Form B (R1-ALT) Item D to read “TOTAL BID PRICE (Items A + B + C) (GST extra) (in figures) \$”  
Item F to read “EVALUATED TOTAL BID PRICE (Items D + E) (GST extra) (in figures) \$”
- Form B (R1-ALT) A.1 b) 525mm C76 – CL V.

Replace: Note all reference to ‘Form B: Prices’ will be replaced with ‘Form B (R1-ALT): Prices’, if the Contractor supplies an alternative substitution submission.

### PART B – BIDDING PROCEDURES

Revise: B17.1(c) to read “Evaluated Total Bid Price”.

**QUESTIONS AND ANSWERS**

Q1: Will the City allow the alternative pipe material of concrete for the 525mm diameter section of the Contract?.

A1: The City would allow concrete pipe C76-CL V as an alternative to the SDR 35 PVC section covering the 525mm diameter pipe only. The Contractor to submit Part A - Bid Submission (Alternative) as response.