

SYNDICATE FLOOD PUMPING STATION UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS
IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: July 12, 2018
BY: Maqbool Hussain
TELEPHONE NO. (204) 453-2301 Ext . 4060

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

DRAWINGS

Replace:

482-2018_Drawing_1-0189F-E0004-001-R0 with 482-2018_Drawing_1-0189F-E0004-001-R2.

NMS FORMAT SPECIFICATIONS

Section 07 61 00 – Metal Roofing System

- Revise: 2.1.1 Roof System: Tradition100-4 on Solid Substrate by Vicwest, **Una-Cla UC-7 by Firestone Building Products Canada or an approved equal in accordance with B7.**
- Revise: 2.1.1.1 Underlayment: Membrane shall be Ice and Water Shield by W.R. Grace, **Clad-Gard SA by Firestone Building Products Canada or an approved equal in accordance with B7.**
- Revise: 2.1.2.1 Thermally responsive clips to be fabricated from a minimum of 0.91 mm (.036") steel, with minimum Z275 galvanized coating designed to accommodate expansion and contraction of the roof sheet. **Clip System shall be Una-Clad UC-7 Clip by Firestone Building Products Canada or an approved equal in accordance with B7.**
- Revise: 2.1.2.2 Roof Fasteners: As specified by manufacturer, to resist wind uplift and sliding snow forces. **Roof Fasteners shall be All-Purpose Fastener by Firestone Building Products Canada or an approved equal in accordance with B7.**
- Revise: 2.1.3.1 Profile: Tradition 100-4, with I-style ribs at 400 mm spacing. **Prefinished Roof Sheet – Kynar 500/Hylar 5000 Pre-Finished Galvanized Steel Architectural Sheet & Coil by Firestone Building Products Canada or an approved equal in accordance with B7.**

Section 21 05 01 – Common Results for Mechanical Work

- Revise: 1.2.1.1 One (1) filter cartridge or set of filter media for each filter or filter bank in addition to final operating set. **Acceptable Manufacturer: Camfil Farr or approved equal in accordance with B7.**

Section 23 33 15 – Dampers – Operating

- Revise: 2.1.8 Acceptable Manufacturers: Greenheck, Price, Ruskin, Ventex, TAMCO, Alumavent, or an approved equal in accordance with B7.

Section 23 34 00 – HVAC Fans

Revise: 2.2.1 Acceptable Manufacturers: Cook, Greenheck, **Twin City, or an approved equal in accordance with B7.**

Replace: Section 23 81 26 (R1) – Air Conditioning Unit.