



509-2018 ADDENDUM 1

HAWTHORNE WASTEWATER PUMPING STATION UPGRADES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: July 25, 2018
BY: Maqbool Hussain
TELEPHONE NO. (204) 453-2301 Ext . 4060

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E - SPECIFICATIONS

Add: E1.3 Municipal Gate Chamber As-Built Drawings:

LD-3244	Structural General Arrangement
LD-3246	Structural – Substructure Elevations and Details
1-0145-A-A0202-001	CSO Outfall Monitoring Hawthorne 3D Isometric Plan

Revise: E9.1.2 (a) **The critical basement elevation is 224.318 m. The Contractor will not allow wastewater to reach 0.5 m below the critical basement elevation.**

Add: E9.1.2 (c) The maximum storage capacity based on PDWF is half an hour.

Revise: E9.2.1 (a) Non-clog, submersible pumping units, each sized to meet or exceed the required capacity. Complete with all required piping, fittings, floats, alarms, back-up generator, pump controls and related appurtenances suitable for temporary installation in a Municipal Gate Chamber upstream of the pumping station. **The Contractor can propose alternatives for wastewater pumping location. The plan should be provided to the City for review.**

NMS FORMAT SPECIFICATIONS

Section 05 50 00 – METAL FABRICATIONS

Delete: 2.13 Aluminum Access Hatch - Exterior

Section 29 50 01 – INSTRUMENTATION SPECIFICATION SHEETS

Revise: 2.1 Instrument Specification Number I-101

Manufacturer and Model: Siemens

Add: 2.1 Instrument Specification Number I-101

Purchase or Quotation:

All requests for purchase or quotation shall reference RFP 449-2014 to receive standardized pricing that the City has negotiated with the vendor.

Contact: Trans-West Company Inc., 126 Bannister Road, Winnipeg, MB

Revise: 2.1 Instrument Specification Number I-102

Manufacturer and Model: Siemens

Add: 2.1 Instrument Specification Number I-102

Purchase or Quotation:

All requests for purchase or quotation shall reference RFP 449-2014 to receive standardized pricing that the City has negotiated with the vendor.

Contact: Trans-West Company Inc., 126 Bannister Road, Winnipeg, MB

Revise: 2.1 Instrument Specification Number I-105

Manufacturer and Model: Siemens

Add: 2.1 Instrument Specification Number I-105

Purchase or Quotation:

All requests for purchase or quotation shall reference RFP 449-2014 to receive standardized pricing that the City has negotiated with the vendor.

Contact: Trans-West Company Inc., 126 Bannister Road, Winnipeg, MB

Section 23 33 15 - DAMPERS - OPERATING

Add: 2.1.8 Acceptable Manufacturers: Greenheck, Price, Ruskin, Ventex, TAMCO, Alumavent, or an approved equal in accordance with B7.

Add: **Section 23 37 13 - DIFFUSERS, REGISTERS AND GRILLES**

GENERAL CLARIFICATIONS

- 1- There is no requirement to sandblast the walls and floors unless otherwise particularly mentioned in the tender drawings and specifications.
- 2- Plywood sheathing, doors and interior walls require painting.
- 3- Building exterior does not require anti-graffiti coating.