



962-2018 ADDENDUM 1

FORT ROUGE TRANSIT BASE STORAGE TRACK 13-24 MECHANICAL UPGRADE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: November 28, 2018
BY: Jeff Horrocks, P.Eng.
TELEPHONE NO. 204 789-2332

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, December 11, 2018.

NMS FORMAT SPECIFICATIONS

Revise: 1.2.7.7 of 21 05 10 to read: Heat recovery units* Tempeff; Ventrol

Revise: 2.7.5.2 of 23 80 10 to read: All controls shall be located on the side of the unit for ease of servicing. Controls located on the top or the bottom of the unit are not acceptable.