


FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB05	0P	5x20mm	0.1
	1P	5x20mm	0.1
	2P	5x20mm	0.1
	3P	5x20mm	0.1
	4P	5x20mm	0.1
	5P	5x20mm	0.1
	6P	5x20mm	0.1
	7P	5x20mm	0.1
	8P	5x20mm	0.1
	9P	5x20mm	0.1
	10P	5x20mm	0.1
	11P	5x20mm	0.1
	12P	5x20mm	0.1
	13P	5x20mm	0.1
	14P	5x20mm	0.1
	15P	5x20mm	0.1
	16P	5x20mm	0.1
	17P	5x20mm	0.1
	18P	5x20mm	0.1
	19P	5x20mm	0.1
	20P	5x20mm	0.1
	21P	5x20mm	0.1
	22P	5x20mm	0.1
	23P	5x20mm	0.1
	24P	5x20mm	0.1
	25P	5x20mm	0.1
	26P	5x20mm	0.1
	27P	5x20mm	0.1
	28P	5x20mm	0.1
	29P	5x20mm	0.1
	30P	5x20mm	0.1
31P	5x20mm	0.1	

DRAWING NUMBER	REFERENCE DRAWINGS
1-0640M-E0076	MOTOR STARTER SCHEMATIC, FN3
1-0640M-E0075	MOTOR STARTER SCHEMATIC, FN2
1-0640M-A0083	LOOP DIAGRAM, CHLR-M640
1-0640M-A0073	LOOP DIAGRAM, CP-M826.UPS01, POWER SUPPLY ALARM
1-0640M-A0072	LOOP DIAGRAM, FSL-M6112, FSL-M6122 & FSL-M6132
1-0640M-A0062	LOOP DIAGRAM, XV-M6144, OUTDOOR INTAKE AIR DAMPER
1-0640M-A0052-57	DISCRETE INPUTS/OUTPUTS, ANALOG INPUTS/OUTPUTS, CP-M826
1-0640M-A0051	POWER DISTRIBUTION, HVAC CONTROL PANEL CP-M826
1-0640M-A0050	PANEL LAYOUT, HVAC CONTROL PANEL CP-M826



		SNC-LAVALIN INC. 148 Notre Dame St. W. Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY: S. BOGHOSIAN	CHECKED BY: B. CLEVEN	DRAWN BY: C. DUBON	APPROVED BY: D. BECKER
SCALE: NTS	ISSUED FOR CONSTRUCTION BY: A. WEISS	DATE: 2019/05/31	DATE: 2019/10/18
ISSUED FOR TENDER AND CONSTRUCTION		2019/10/18	SB BC
NO.	REVISIONS	DATE	DESIGN/CHECK



THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

MCPHILLIPS PUMPING STATION
 AUTOMATION - WIRING DIAGRAM
 HVAC CONTROL PANEL CP-M826
 DISCRETE INPUTS RACK 0, MODULE 5

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0640M-A0054	001	00	A1