


### GENERAL NOTES


- DASHED LINES DENOTE EQUIPMENT, AND ASSOCIATED WIRING TO BE DEMOLISHED.
- EXISTING DISTRIBUTION TO BE DEMOLISHED THROUGHOUT. REFER TO OVERALL ELECTRICAL PHASING.
- REVIEW EXISTING BRANCH WIRING AND FEEDERS THROUGHOUT, AND PROVIDE UPDATED SKETCH OF ELECTRICAL DISTRIBUTION SCHEMATICS INDICATING REMAINING LOADS AND NUMBER OF BRANCH CIRCUIT POSITIONS WHERE DEVICES AND/OR EQUIPMENT NOT DELETED.

### KEY NOTES

- VERIFY PUMPS CONNECTED.
- DEMOLISH EXISTING SWITCHBOARD / DISTRIBUTION PANEL.
- DEMOLISH EXISTING MAIN DISCONNECT SWITCH AND UTILITY METER.
- OVERHEAD LINE TO BE DEMOLISHED BY MB HYDRO.
- RELOCATE TO LOWER LEVEL.
- DEMOLISH TRANSFORMER, DEGRADED WINDING INSULATION AND SECONDARY VOLTAGE OUTPUT IS BELOW RATED.
- ARENA NORTH WALL EXHAUST FANS. VERIFY QUANTITY AND LOCATIONS.
- VERIFY GOLF COURSE IRRIGATION PUMP LOCATION.



This is a print of a document that has been electronically authenticated with technology authorized by the APEGM. The original is in electronic form.



This drawing must not be scaled. The contractor shall verify all dimensions and other data on site prior to commencement of work. Discrepancies, errors, and omissions are to be reported to Public City Architecture Inc. prior to proceeding with the Work.  
Drawings and specifications as instruments of service are the property of Public City Architecture Inc. the copyright in the same being reserved.  
No reproduction or revision to these drawings may be made without the permission of Public City Architecture Inc. and when made, must bear their name. All prints to be returned to Public City Architecture Inc. upon request.

Project  
ST. JAMES CIVIC CENTRE

Drawing  
ELECTRICAL SINGLE LINE DIAGRAM - EXISTING

Drawn By: JA Review By: MP  
Scale: NTS Tender No: 1176-2019  
Date: 11/06/19  
Sheet: E5.1