

**KEY NOTES**


- 1 EXISTING RTU SERVING POOL UNIT TO BE DEMOLISHED COMPLETE WITH ADDITIONAL DUCTWORK AND PREHEAT COIL. COORDINATE POWER DISCONNECTION WITH ELECTRICAL.
- 2 EXISTING COMBUSTION AIR SUPPLY UNIT TO BE DEMOLISHED. COORDINATE POWER DISCONNECTION WITH ELECTRICAL.
- 3 EXISTING CONDENSING UNIT TO BE DEMOLISHED COMPLETE WITH REFRIGERATION PIPING. COORDINATE POWER DISCONNECTION WITH ELECTRICAL.
- 4 EXISTING EXHAUST HOOD TO BE DEMOLISHED.
- 5 EXISTING EXHAUST FAN TO BE DEMOLISHED.
- 6 EXISTING EXHAUST FAN TO BE REMOVED.
- 7 EXISTING DUCTWORK WITHIN SHAFT TO BE REMOVED.
- 8 EXISTING CHIMNEY WITHIN SHAFT TO BE REMOVED ENTIRELY.
- 9 EXISTING VENTILATION AND COMBUSTION AIR DUCTWORK TO BE REMOVED ENTIRELY.
- 10 DEMOLISH EXISTING RELIEF AIR DUCT.
- 11 EXISTING DUCT RISER TO REMAIN. REFER TO SHEETS MH2.3 AND MH3.1 FOR CONTINUATION.

**PUBLICCITY**  
 Public City Architecture Inc  
 11-600 Clifton Street  
 Winnipeg, Manitoba  
 R3G 2X6 204 475 9323  
 publiccityarchitecture.com

Rev. No. Date Revision Notes  
 0 19-11-06 Issued for Construction



This is a print of a document that has been electronically authenticated with technology authorized by the APEGM. The original is in electronic form.



LEVEL 2 - HVAC DEMOLITION 1/32" = 1'-0" MH2.2

This drawing must not be scaled. The contractors shall verify all dimensions and other data on site prior to commencement of work. Discrepancies, errors, and omissions are to be reported to Public City Architecture Inc. prior to proceeding with the Work.  
 Drawings and specifications as instruments of service are the property of Public City Architecture Inc. the copyright in the same being reserved.  
 No reproduction or revision to these drawings may be made without the permission of Public City Architecture Inc. and when made, must bear their name. All prints to be returned to Public City Architecture Inc. upon request.

Project  
**ST. JAMES CIVIC CENTRE**

Drawing  
**LEVEL 2 DEMOLITION - HVAC PLAN**

Drawn By: GC Review By: JS  
 Scale: 3/32" = 1'-0" Tender No: 1176-2019  
 Date: 11/06/19  
 Sheet: **MH2.2**