

1 SECOND FLOOR FRAMING PLAN


SCALE: 3/32"=1'-0"

FRAMING PLAN NOTES:

- DESIGN LOADS:
 - SUPERIMPOSED DEAD LOAD = 1.3 kPa
 - LIVE LOAD = 4.8 kPa (PER EXISTING DRAWINGS)
- FOR LINTELS AT OPENINGS IN NEW MASONRY WALLS, REFER TO GENERAL NOTES ON DRAWING S1.1. REFER TO ARCH./MECH./ELEC. FOR LOCATIONS.
- FOR LINTELS AT OPENINGS IN EXISTING MASONRY WALLS, REFER TO TYPICAL DETAIL ON DRAWING S1.2. REFER TO ARCH./MECH./ELEC. FOR LOCATIONS. SEE TYPICAL DETAIL ON DRAWING S1.2 FOR LINTEL SUPPORT AT EXISTING CONCRETE WALLS OR COLUMNS.
- FOR CORE LOCATIONS THROUGH EXISTING SLABS AND CONCRETE WALLS, REFER TO ARCH. / MECH. / ELEC. DRAWINGS. MAXIMUM CORE SIZE TO BE 6" Ø. MINIMUM SPACING BETWEEN CORES TO BE MAXIMUM OF 2x CORE DIAMETER C/C OR 4" EDGE-TO-EDGE. SCAN FOR REBAR PRIOR TO CORING. EXISTING REBAR NOT TO BE CORED THROUGH.
- PROVIDE CONCRETE INFILL RW 10M @ 12" E.W. BOTTOM (MIN. 2 EACH DIRECTION) AT EXISTING FLOOR GRILLES & SMALL OPENINGS (<12" IN SHORT DIRECTION) THAT ARE TO BE REMOVED. CONCRETE INFILL TO MATCH SLAB THICKNESS (± 1/2", SITE CONFIRM). SEE ARCH. DEMOLITION DRAWINGS FOR LOCATIONS.

SUSPENDED SECURITY GRILLE BELOW (SEE SECTION). SEE ARCH. FOR LOCATION. APPROX. WEIGHT = 1.5 kN/m.

SLAB SCHEDULE	
MARK	DESCRIPTION
S1	6" COMPOSITE SLAB ON 3" x 22 Ga. STEEL DECK REINF: 6" x 6" x W2.9 x W2.9 W.W.M.
S2	3/4" PLYWOOD ON 3" x 22 Ga. STEEL DECK ON 3625162-33 (3 5/8" x 20 GA.) @ 15" O.C. STEEL STUD POWY WALLS @ 6" O.C. MAX.



This drawing must not be scaled. The contractors shall verify all dimensions and other data on site prior to commencement of work. Discrepancies, errors, and omissions are to be reported to Public City Architecture Inc. prior to proceeding with the Work.

Drawings and specifications as instruments of service are the property of Public City Architecture Inc.; the copyright in the same being reserved.

No reproduction or revision to these drawings may be made without the permission of Public City Architecture Inc., and when made, must bear their name. All prints to be returned to Public City Architecture Inc. upon request.

Project
St. James Civic Centre
2055 Ness Avenue

Drawing
SECOND FLOOR
FRAMING PLAN

Drawn By: MA
Scale: As Noted
Date: 11/06/2019
Reviewed By: DK
Tender No.: 1176-2019
Sheet: S2.2