



1195-2019 ADDENDUM 4

WAYFINDING PHASE 1 CONSTRUCTION ST. JAMES-ASSINIBOIA CENTENNIAL POOL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: December 9, 2019
BY: Lou M. Chubenko
TELEPHONE NO. 204 470-7881

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

QUESTIONS AND ANSWERS

Q1: Can you advise or clarify on how you envision the information transfer between the sign and the pool building/computer.

A1: The fibre optic connection was intended for sign data, and the wireless provisions are for the programming of the unit. Refer to Drawing Note 1 on 1195-2019_Drawing_E2.0-R0 that indicates that the requirements are to be confirmed with the electronic sign supplier.

Clarification: Sign installation to include provisions for data and for programming to meet the specific requirements of the proposed electronic sign product.