



494-2019 ADDENDUM 1

STEAM BOILER REPLACEMENT – 215 TECUMSEH STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 24, 2019
BY: Greg Kucel
TELEPHONE NO. 204 986-3429

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Replace: 494-2019_NMS_Specification with Addendum_01_494-2019_NMS_Specification
- Clarification of E3.2: The existing condensate tanks/pumps include 1 condensate tank and 2 associated pumps in the boiler room, and 1 condensate tank and 1 associated pump, in the north-west corner of the carpenter shop.
- Clarification of E4.3: The new condensate tanks/pumps include 1 condensate tank and 2 associated pumps in the boiler room, and 1 condensate tank and 1 associated pump in the north-west corner of the carpenter shop. The new condensate tanks and pumps shall be the same size and capacity as existing.
- Add: E4.9 Replace the two (2) 6” existing steam isolation valves and associated piping with new in the boiler room. Piping from the valves to the boiler shall be new.

NMS SPECIFICATIONS

- Replace: 494-2019_NMS_Specification with 494-2019_Addendum_1-NMS_Specification