



17-2020 ADDENDUM 2

FORT ROUGE TRANSIT BASE STORAGE TRACK 25-36 MECHANICAL UPGRADE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: February 7, 2020
BY: Jeff Horrocks, P.Eng.
TELEPHONE NO. 204 789-2332

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: 1.2.8.1 of 21 05 10 to read: Temperature control system* Johnson Controls (Metasys) (Winnipeg Office)

Revise: 1.3.1 of 25 10 10 to read: The City of Winnipeg has an existing central monitoring system in place. Where DDC points are identified as centrally monitored points, the Controls Contractor shall provide and install required hardware and software to interface to The City's Johnson Controls Metasys EA servers and workstations. These are located at the Central Control Offices, 510 Main Street, Winnipeg, Manitoba (ie City Hall). All controls work to be completed by Johnson Controls Winnipeg Office.

Add: 17-2020_Addendum_2-NMS_Appendix B – Asbestos Assessment Tracks 25-36.

Add: 17-2020_Addendum_2-NMS_Appendix C – Asbestos Inventory Control.

DRAWINGS

Replace: 17-2020_Drawing_M1.2-R0 with 17-2020_Addendum_2-Drawing_M1.2-R1.

Replace: 17-2020_Drawing_M2.2-R0 with 17-2020_Addendum_2-Drawing_M2.2-R1.

Replace: 17-2020_Drawing_M4.2-R0 with 17-2020_Addendum_2-Drawing_M4.2-R1.

Replace: 17-2020_Drawing_E1.3-R0 with 17-2020_Addendum_2-Drawing_E1.3-R1.

Replace: 17-2020_Drawing_E2.2-R0 with 17-2020_Addendum_2-Drawing_E2.2-R1.

Replace: 17-2020_Drawing_S1.1-R0 with 17-2020_Addendum_2-Drawing_S1.1-R1.