



235-2020 ADDENDUM 2

SUPPLY AND DELIVERY OF CAST-IRON CONTROL GATES FOR THE CANORA OUTFALL CHAMBER UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: April 20, 2020
BY: Colin Siepman
TELEPHONE NO. 204 986-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E6.2 (i) to read: Acceptable leakage: 1.24 litres /minute per meter of seated perimeter.