



297-2020 ADDENDUM 2

SUPPLY OF PUMPING EQUIPMENT AND VALVES FOR WESTWOOD WASTEWATER PUMPING STATION UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: May 27, 2020
BY: Blair Moore, P.Eng.
TELEPHONE NO. 204 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

NMS SPECIFICATIONS

Section 43 21 13 – CENTRIFUGAL SHAFT PUMPS

Revise: 2.1.2.5.6 to read: Size of Sphere Impeller Shall Pass: 76 mm (3.0 in)