

PLAN REVIEW REPORT

Applicant: City of Winnipeg Bonivital Indoor Pool
Address: 1215 Archibald St. Winnipeg, MB.
Date: 6 January 2020
Approved: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Pending (See Conditions Below) <input type="checkbox"/>
Reviewed by: Dave Nedecky & Greg Marsh

PLAN REVIEW REPORT

SUBJECT: *Plans dated December 27, 2019.*

Approval Subject To The Following Conditions As Required By Manitoba Regulation 132/97, *Swimming Pools And Other Water Recreational Facilities Regulation*:

NOTE: The applicant is responsible for ensuring all contractors/companies involved with the construction or alteration of this facility are provided with copies of this plan approval.

1. Upon completion of construction or alteration, a certificate of a professional engineer certifying that the completed construction or alteration of the facility is in accordance with the design and specifications must be submitted to this department *prior to an opening inspection.*
2. The drains and other water recirculation facilities must be designed constructed and operated in such a manner to prevent entrapment of a bather due to suction or any other means.

3. Equipment must be installed that adds disinfectant to the water of the pool *automatically* at all times.
4. The recirculation system of the recreational water facility, including wading pools must be capable of effectively circulating the water over the entire surface and depth of the pool.
5. The water in the pool and recirculation system must be separated from the make-up water supply and from the sewer or drainage system into which it drains by air gaps or other backflow preventers.
6. Ensure the pool facility has continuous filtration of re-circulated water.
7. *Flow Rates and filter sizes are sufficient to provide adequate turnovers for pool water treatment.*

NOTE: ANY FURTHER CHANGES TO THE DESIGN AND/OR CONSTRUCTION OF THIS FACILITY MUST BE SUBMITTED IN AN AMENDMENT TO THE ORIGINALLY SUBMITTED PLAN, COMPLETE WITH ENGINEER STAMPED DRAWINGS TO THE AREA PUBLIC HEALTH INSPECTOR FOR REVIEW AND APPROVAL.

PRIOR TO THE FACILITY OPENING FOR OPERATION, A HEALTH PERMIT IS REQUIRED. PLEASE SUBMIT THE ATTACHED POOL PERMIT APPLICATION FORM, AND CONTACT DAVE NEDECKY AT 204-470-7789 TO ARRANGE FOR AN OPENING PERMIT INSPECTION.