



753-2020 ADDENDUM 3

NORTHEAST INTERCEPTOR RIVER CROSSING FLOW MONITORING INSTRUMENTATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE TENDER

ISSUED: December 3, 2020
BY: Scott Symons
TELEPHONE NO. 204 928-7410

THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

NMS SPECIFICATIONS

Section 16010 Common Work Results For Electrical

Add: 3.4.1.1.2 Customer Service Termination Enclosure and Metering enclosure may be painted steel.

Section 16440 Disconnect Switches Fused Non-Fused

Add: 1.3.1.1 Disconnect switches in non-corrosive areas may be rated NEMA 3R.

Section 16471 Panelboards – Breaker Type

Add: 2.1.2.1.1 Breaker panelboards mounted inside and protected by NEMA 4X enclosure may be rated NEMA 3R.

Section 17010 Instrumentation and Controls

Add: 2.2.1.1 Control panels mounted inside and protected by NEMA 4X enclosure may be rated NEMA 12.

Section 17100 Programmable Logic Controllers

Add: 2.1.1.6.1 The constant voltage regulating transformer and surge suppressor are not required where the UPS is rated for the same or greater surge level suppression as the specified model.

Delete: 2.1.2

Delete: 2.1.2.1

QUESTIONS AND ANSWERS

Q1: Does the disconnect have to be NEMA 4X? It is already protected by CSTE enclosure.

A1: DWG E-1002 note says the disconnect is mounted to CSTE Enclosure. The disconnect switch should be mounted outside.