



754-2020 ADDENDUM 2

LANDFILL CELL SITE WORK AND LINER CONSTRUCTION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: March 9, 2021
BY: A. Raichura
TELEPHONE NO. 204 986-2962

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

Q1: Per Section E4.8, can you clarify that topsoil and sod are actually expected in all grassed areas that are disturbed during construction?

A1: Topsoil and sod application areas are not shown on the drawings, and it should have been observed during the pre-bid site meeting that there are no grassed areas within the construction area that would warrant topsoil and sod application. Therefore, it is a safe assumption that topsoil and sod are not expected for this contract.

Q2: If moisture conditioning of the clay liner is required, is the Contractor responsible for sourcing out a clean water supply or is there access to treated water anywhere on site?

A2: The Contractor will be responsible to supply their own water for moisture conditioning. There are stormwater retention ponds on site that may have water available for us, but this water is prioritized for site (composting) operations, so there is no guarantee that this water will be available.

Q3: Can you confirm that a site trailer for the CA is required?

A3: Site trailer is not required for the Contract Administrator (CA). A site trailer may be needed for the Contractor's supervisor & crew. Pending COVID protocols once construction starts, the admin building at Brady may be available for regular site meetings.