



## 785-2020 ADDENDUM 4

PROFESSIONAL ENGINEERING CONSULTING SERVICES FOR DESIGN  
AND CONTRACT ADMINISTRATION OF THE NEWPCC PRIMARY  
CLARIFICATION UPGRADES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: March 16, 2021  
BY: Jaimee Sekanjako  
TELEPHONE NO. 204-986-3266

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

### **PART B – BIDDING PROCEDURES**

Revise: B9.6 (b) to read: Services proposed by Proponents which shall be detailed in accordance with B9.2.1 or B9.3.1.

### **PART D – SUPPLEMENTAL CONDITIONS**

Delete: D7.1.6 (b)

Delete: D7.1.6 (c)

### **QUESTIONS AND ANSWERS**

- Q1: Can the City confirm that the scope of work to carry out the condition assessments of the primary clarifiers 4 and 5 traveling bridge collectors is to be included in the preliminary design scope of work as called for in Section D7.1.4 and further defined in Section D9.1.4?
- A1: Yes. The scope of work to carry out the condition assessments of Primary Clarifiers 4 and 5 traveling bridge collectors is to be included in the preliminary design scope of work in Section D7.1.4 and further defined in Section D9.1.4
- Q2: Can the City confirm that the “Detailed design, tender and contract administration services for Scope of Services described in D9.1.4” as described in Section D7.1.6 (C) is out of scope for preliminary design but is the scope of work which is to be provided for as an optional service as called for in Section B9.6?
- A2: D7.1.6(c) has been removed. The detailed design, tender, and contract administration services for Scope of Services described in D9.1.4 should be included in Optional Services as called for in Section B9.6.

- Q3: Section B9.6(a) appears to call the condition assessment scope of work identified in D9.1.4 as part of the optional services. It would make sense to us that the condition assessment is part of preliminary design and that the “detailed design, tender and contract administration” would be part of the Optional Services once the assessment is complete and recommendations are given.
- A3: To clarify, for the work identified in D9.1.4, Preliminary Design should be included in the Scope of Work and Detailed Design, Tender and Contract Administration for this work should be part of Optional Services.
- Q4: There appears to be a circular reference between B9.6(b) and D7.4.1 which may need to be addressed in the RFP.
- A4: Reference to D7.4.1 has been removed from B9.6(b)
- Q5: Will there be access to past work CAD files. As AECOM was the author of the technical memo and conceptual drawings for the scum building in Appendix 3 of this RFP, having access to AECOM's CAD files would allow some efficiencies in that we would not have to regenerate information in the preliminary design drawings, should we be the selected consultant to carry out this work.
- A5: Upon signing a Non Disclosure agreement, access to relevant CAD files will be given to the successful proponent.
- Q6: In the RFP, section D7.1.2 the scum pipes are to be relined. After meeting on site, we are still unsure around the full requirements for this. Which pipes? Sizes? Etc.
- A6: There are Four scum pipes to be relined. One from each of the clarifiers to the scum pipe header in the lower gallery and one from the centre ring sluice gate to the same header. The pipes are 14” in diameter. The exact lengths can be determined from the attached drawing.