

276-2021 ADDENDUM 2

KEEWATIN UNDERPASS PUMPING STATION – 2021 UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: 2021-06-07
BY: Brian Cleven
TELEPHONE NO. 204 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **June 10, 2021**.

NMS SPECIFICATIONS

Revise: 26 50 00 clause 2.5.1 to read:

Luminaires:

- .1 **Type A**
 - .1 Eaton 4VT2-LD5-8-DR-UNV-L840-CD-U
 - .2 Delviro VT4S-60C-4K-U-FR-GRY-V-BFCX-N-N
 - .3 Or approved equal in accordance with B7.
- .2 **Type B**
 - .1 LuxLogic W-CR-WM-45W-40-70-UNV-D-DB
 - .2 Or approved equal in accordance with B7.
- .3 **Type C**
 - .1 Eaton EVLEDCX2C701
 - .2 Appleton CJLCL22CBUG
 - .3 Or approved equal in accordance with B7.
- .4 **Type D**
 - .1 Eaton EVLEDBX2C701
 - .2 Appleton CJLWL22CBUG
 - .3 Or approved equal in accordance with B7.
- .5 **Type EA**
 - .1 Emergi-Lite EF39PDM-LG
 - .2 Or approved equal in accordance with B7.

Revise: 33 41 01 clause 2.1.5 to read:

Acceptable Pump Manufacturers

- .1 Pentair / Fairbanks
- .2 Cascade
- .3 Flowserve
- .4 Xylem
- .5 **Ruhrpumpen**
- .6 Or approved equal in accordance with B7.

Add: 33 41 01 clause 2.1.15.13:

Vibration monitoring: Provide vibration sensor/transmitter on each motor to monitor pump motor vibration. Transmitter to be equipped with a loop-powered 4-20mA output, and have CSA or cULus approval or equivalent. The pump/motor manufacturer shall recommend appropriate vibration alarm limits; two alarm limits shall be defined: Hi and Hi-Hi. Standard of acceptance: IMI Sensors 641B61, IFM VKV021, or approved equal in accordance with B7.