



281-2021 ADDENDUM 1

SUPPLY AND DELIVERY OF HEATED PASSENGER SHELTERS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 6, 2021
BY: Adam Budowski
TELEPHONE NO. 204 391-0070

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time on **July 19, 2021**.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D9.1 to read: All Goods shall be delivered by December 13, 2021 f.o.b. destination, freight prepaid to:
Attn: Jimmy Marnoch
421 Osborne Street
Winnipeg, Manitoba, Canada
R3L 2A2

Add: D9.1.1 Goods may be delivered in as many shipments that meets the delivery schedule below:
(a) a total of two (2) heated shelters are delivered by November 22, 2021;
(b) a total of six (6) heated shelters are delivered by November 29, 2021;
(c) a total of ten (10) heated shelters are delivered by December 6, 2021; and
(d) all 14 heated shelters are delivered by December 13, 2021.

Revise: D9.2 to read: The Contractor shall confirm each delivery with the Contract Administrator or his/her designate, at least two (2) Business Days before delivery.

PART E – SPECIFICATIONS

Revise: E4.1 to read: The Work of this specification comprises the furnishing of all labour, equipment and materials required to complete the supply, of passenger shelters and related Work as shown on the Drawings and as hereinafter specified, including, but not necessarily confined to the following:

- (a) Supply of heated shelters as per design Drawings.
- (b) Coordination with electrical contractor for connection of new shelters.
- (c) Coordination with site works contractor

Revise: E4.2 to read: The fabrication of shelters as specified in this Section shall include the following:

(a) Provide electrical wiring, diagrams for wiring and access for lighting and heaters to electrical contractor. All wiring runs must be hidden from view within the shelter structure and must be vandalism proof.

(b) Provide a detailed parts list to Winnipeg Transit including product number, product description, colour and options for all components of the shelters.

QUESTIONS AND ANSWERS

Q1: There is reference to bidder providing 'contract securities' (B14.2) and further mention on the bid proposal page 2, item 6 mentions "where bid security is required". However, there are no specific bonding requirements and the G1 Bid Security Form has not been provided.

A1: Bid security is not required.

Q2: Who is installing the heated shelters?

A2: Winnipeg Transit staff are installing the heated shelters.

Q3: Who is installing the concrete pads for these shelters?

A3: This work is being contracted out by the City as part of a separate Tender.

Q4: How is the heater and light controlled?

A4: There shall be a tamperproof thermostat in the heater; the lights are controlled with a photo cell and contactor.