



## 310-2021 ADDENDUM 3

### CLARA HUGHES PARK PLAYGROUND REDEVELOPMENT

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
REQUEST FOR PROPOSAL**

ISSUED: May 26, 2021  
BY: Ian Macdonald  
TELEPHONE NO. 204 – 451-3069

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE REQUEST FOR PROPOSAL AND  
SHALL FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: Ar20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Proposal may render your Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **June 11, 2021**.

#### **PART E – SPECIFICATIONS**

Revise: E21.1.1 (d) to read:

- (d) The method of installation for the Senior Play Equipment in the existing wading pool basin shall be either:
- (i) a ground surface metal stringer system, in which a series of metal stringers are welded to the posts of the Play Equipment, and thus the Play Equipment floats on top of the level granular surface, rather than being installed into poured in placed concrete footings. The metal stringer support system must be designed and approved by the playground equipment manufacturer. Prior to authorizing acceptance of anchoring method, the Contractor will have to provide documents from the play equipment manufacturer that they have designed and approved the system of anchoring.
  - (ii) surface mount system, in which threaded rods are chemically fastened into the pool basin through a levelling pad of grout or high strength concrete. Posts are then fastened to the leveling pad via predrilled base plates, which the threaded rods pass through. The surface mount system must be designed and approved by the playground equipment manufacturer. Prior to authorizing acceptance of anchoring method, the Contractor will have to provide documents from the play equipment manufacturer that they have designed and approved the system of anchoring.

E21.3.3 (b) to read:

- (b) The method of installation for the Play Equipment in the wading pool basin shall be a ground surface metal stringer system OR surface mount system as previously indicated in section E21.1.1(d)

Note: Specification revised to include approved play equipment surface mount system as shown on Drawing C.21-7-R0.

## **DRAWINGS**

Replace: 310-2021\_Drawing\_C.21-1-R0 with 310-2021\_Drawing\_C.21-1-R1

Note: Revised Drawing indicates location of existing pool drain line.

Add: 310-2021\_Drawing\_C.21-7-R0

Note: Detail for approved play equipment surface mount system.