

507-2021 ADDENDUM 1

PIPELINE ACCESS MODIFICATIONS, CLEANING & SUPPORT FOR RIVER CROSSING INSPECTIONS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: July 8, 2022
BY: Tanner Beavis
TELEPHONE NO. 204-928-9200

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D12.1(a) to read: commercial general liability insurance, in the amount of at least two million dollars (\$2,000,000.00) inclusive, with The City of Winnipeg and CPR added as an additional insured, with a cross-liability clause, such liability policy to also contain contractual liability, unlicensed motor vehicle liability, non-owned automobile liability, sudden and accidental pollution liability and products and completed operations, to remain in place at all times during the performance of the Work and throughout the warranty period.
- Revise: D12.1(c) to read: all risks Installation Floater carrying adequate limits to cover all machinery, equipment, supplies and/or materials intended to enter into and form part of any installation.
- Add: D12.1 (d) Contractors Pollution Liability (CPL) insurance in the amount of no less than one million dollars (\$1,000,000) per occurrence and two million dollars (\$2,000,000) aggregate covering third party injury and property damage claims including clean-up costs and transported cargo as a result of pollution conditions arising from the Contractor's operations and completed operations. Such policy shall name the City as an additional insured and remain in place for a minimum of twelve (12) months following Total Performance.

DRAWINGS

Replace: 507-2021_Drawing_1 0798E-C0006-001-RC with 507-2021_Addendum 1_Drawing_1-0798E-C0006-001-RD.

QUESTIONS AND ANSWERS

- Q1: Site 8 – the construction method indicates driven soldier piles; can the Contractor elect for a different method of pile installation.
- A1: The Contractor may select alternate means of pile installation. Installation methods such as pre-boring piles, must utilize backfill methods between the pile and the pre-bore to maintain intimate contact between the pile and the ground.
- Q2: Please accept our request for a closing date extension.
- A2: An extension of the Tender closing date will not be provided at this time.