

536-2021 ADDENDUM 1

BONNYCASTLE PARK LIGHTING UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 27, 2021
BY: Rob Zanewich
TELEPHONE NO. 204 232 2800

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **September 1, 2021.**

PART E – SPECIFICATIONS

Revise: E9.3.4 (a) to read:

Light Pole and Decorative Base Shroud

- (a) Manufacturer: Lumec by Signify
Product Code: SPR4D-8-B104-G-BKTX with Custom Base Plate to match existing bolt pattern for 2.4m (8') high poles and SPR4D-12- B104-G-BKTX with Custom Base Plate to match existing bolt pattern for 3.65m (12') high poles; or
- (b) Manufacturer: Prairie Pole
Project Code: PRA 4" Round Heavy Wall Steel @ 3.65m (12') with Custom Base Plate to match existing bolt pattern, poles galvanized and then bead blasted, then powder coated black c/w tenon, and PRA 4" Round Heavy Wall Steel @ 2.4m (8') with Custom Base Plate to match existing bolt pattern, poles galvanized and then bead blasted, then powder coated black c/w tenon; or
- (c) Manufacturer: Valmont
Product Code: 4RH-08-GALV-PC-GB with Custom Base Plate to match existing bolt pattern for 2.4m (8') high poles and 4RH-12-GALV-PC-GB with Custom Base Plate to match existing bolt pattern for 3.65m (12') high poles.
- (d) Poles shall meet latest CAN/CSA or AASHTO design code, welding to meet CSA W59.
- (e) Decorative base covers/shrouds shall be HAPCO "Bristol" model or VALMONT 1Q01A0-GB. Decorative base cover to be powder coated gloss black to match colour of pole and luminaire.

Revise: E9.3.5 to read:

Luminaire

- (a) Manufacturer: Lumenpulse
Product Code: PUR100Y CSL S60 30K CR170 5S BKTX DIM SP – 120 Volt and PUR100Y CSL S60 30K CR170 5S BKTX DIM SP – 347 Volt; or
- (b) Manufacturer: Lumec by Signify
Product Code: MPTC-55W48LED-3K-G3-LE5-120V-DMG-BKTX and MPTC-55W48LED-3K-G3-LE5-347V-DMG-BKTX; or
- (c) Manufacturer: Hubbell
Product Code: UR20-24L-65-3K7-5W-UNV-PT24-GB and UR20-24L-65-3K7-5W-347-PT24-GB.
- (d) Or approved substitution in accordance with B7. Any proposed substitutes must be on the approved products list for Manitoba Hydro's commercial Power Smart Program.

- (e) Final locations for new light to be approved by the Contract Administrator. The Contractor shall meet with the City of Winnipeg's Park Electrician and Contract Administrator. after the start-up meeting to accurately determine the light and cable locations.
- (f) Luminaires to be CSA certified and rated for -40°C minimum ambient temperature. Luminaire to be complete with minimum 5-year fixture warranty.
- (g) Driver to have PF > 90%, THD < 20%.
- (h) Surge Suppression to be easily serviceable and must meet or exceed Cat C Low (IEEE C62.41.2).

Revise: E9.3.8 (b) to read:

Breaker shall be lockable in the "off" position and be appropriately sized to carry the load of all the lights on the circuit.