



61-2021 ADDENDUM 1

BERNADINE STRADFORD PARK PLAYGROUND REDEVELOPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 17, 2021
BY: Ian Macdonald
TELEPHONE NO. 204 451-3069

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Add: E18.3.1(b)(iii): All ramps with slope 5% or greater shall provide a handrail as per the 2015 City of Winnipeg Accessibility Design Standard: Section 1.1.5.

Delete: E18.3.2(a)(i): Contractor shall use threadlock, per E19.2.4, on all hardware for playground equipment assembled on site by Contractor, as per Manufacturer's written specifications and instructions.

Note: Threadlock is only required on swingsets

DRAWINGS

Replace: 61-2021_Drawing_B58.D2-R0 with 61-2021_Drawing_B58.D2-R1

Note: Swingset and Bench Removals are BY OTHERS