

		B.M. ELEV.					174	ENGINEER'S SEAL		
	С	CONS	TRUCTION COMPLETION DATE: YYYY MM DD					GS oup		
ENGINEERS GEOSCIENTISTS MANITOBA						DESIGNED BY	DG	CHECKED BY	JAB	
cate of Authorization						DRAWN BY	RG	APPROVED BY	JAB	
KGS Group						SCALE:		RELEASED FOR		
No. 245		1	RE-ISSUED FOR CONSTRUCTION	2022 07 05	j 9743		NTS	CONSTRUCTION		CONSULTANT DRAWING NUMBER
NO. 240		0	ISSUED FOR CONSTRUCTION	2022 05 18	JAB					
	Ν	NO.	REVISIONS	DATE	BY	DATE	2022 03 09	DATE		21-2017-015_A5.1

FUSE SCHEDULE						
TB	IDENTIFIER	SIZE	RATING			
TB21	F2011	5X20mm	5A TD			
	F2012	5X20mm	5A FA			
	F2013	5X20mm	1A FA			
	F2014	5x20mm	1A FA			
	F2015	5x20mm	1A FA			
	F 2211	5x20mm	5A TD			
TB23	F 2212	5x20mm	5A FA			
	F 2213	5x20mm	1A FA			
	ST ACTING E DELAY					

ELECTRONIC CIRCUIT PROTECTION SCHEDULE SIZE ΤB IDENTIFIER RATING CB-20121 12.5X80mm 1A CLASS 2 TB31 CB-20122 12.5X80mm 1A CLASS 2 CB-20123 12.5X80mm 1A CLASS 2 12.5X80mm 1A CLASS 2 CB-22121 CB-22122 12.5X80mm 1A CLASS 2 TB33 CB-22123 12.5X80mm 1A CLASS 2

POWER CONSUPTION	SCHEDULE AT 24	VDC FROM CP-F8	000				
LOAD	RM01 CURRENT (mA)	RM02 CURRENT (mA)	NOTES				
PLC-F8000-A	1650		1				
PLC-F8000-B		1650	1				
NSW-F8300	417	417	2				
NSW-F8310	417	417	2				
NSW-F8320	417	417	2				
LED24V15	1000		2				
NGW-F8100	200		2				
ND-F8100-1 RACK	800	800	2				
ND-F8100-1 SEGMENT F8110	54		3				
ND-F8100-1 SEGMENT F8120	182		3				
RIO-F8000-1	5113	4993	3				
FIT-F87021	380		1				
FIT-F87031	380		1				
FIT-F207703	380		1				
FIT-F207713	380		1				
FIT-F07723		380	1				
FIT-F07804		380	1				
FIT-F07713		380	1				
TOTAL	11770	9834					
NOTES 1. BASED ON 55W OF POWER CONSUMPTION. 2. BASED ON DATA SHEET. 3. BASED ON LOAD CALCULATION.							

 \bigcirc THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT Winnipeg ENGINEERING DIVISION NORTH END SEWAGE TREATMENT PLANT (NEWPCC) INTERIM PHOSPHOROUS REMOVAL AUTOMATION BUILDING 101 CP-F8000 POWER DISTRIBUTION SCHEMATIC ER CITY DRAWING NUMBER 1-0101-ACBD-F201-001 102 SHEET **3** OF **8** FILE PATH: \\192.168.0.226\r-data\Projects\2021\21-0107-015\Dwg\Elec\ADDENDUM\ FILE NAME: 1-0101-ACBD-F201-001.dwg

GENERAL NOTES: