



FLOOR PLAN – POWER
SCALE 1:50

- NOTES:**
- DISCONNECT FOR PDC UNITS WITH 1000A MOLDED CASE SWITCH ARE IN CSA 2 ENCLOSURE. SUPPORT SYSTEM ADJACENT TO PDC UNITS.
 - CABLE TRAY INFORMATION LOCATED IN "RACEWAY SCHEDULE" SPECIFICATION.
 - ELECTRICAL INFORMATION ASSOCIATED WITH MECHANICAL AND PROCESS EQUIPMENT IS LOCATED IN SPECIFICATION FOR MOTOR AND PANEL SCHEDULES.
 - WIRE AND CABLE INFORMATION LOCATED IN CABLE LIST IN SPECIFICATION.
 - UV CONTROL PANEL (UVCP1) AND UV SYSTEM CONTROL CENTRE (SCC) REQUIREMENTS LOCATED IN DIVISION 17 OF THE SPECIFICATION.

AS BUILT PER
COMSTOCK CANADA
August 15 2007

FOR REFERENCE ONLY

AECOM
As of January 3, 2009,
EarthTech became AECOM
Canada Ltd.

AECOM AS-CONSTRUCTED
SIG..... DATE.....

APEGM
Certificate of Authorization
AECOM Canada Ltd.
Original dated on:
No. 4671 Date: 2005/02/18

B.M. ELEV.	EARTH TECH		ENGINEER'S SEAL ORIGINAL SIGNED BY P. STRYK FEB. 18/05	THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT	
	Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381			NEWPCC - SECONDARY EFFLUENT UV DISINFECTION FACILITY	
DESIGNED BY GNS	CHECKED BY PS	CITY FILE NUMBER		SHEET 4 OF 15	
DRAWN BY CPG	APPROVED BY DT	CITY DRAWING NUMBER		1-0101U-E0006-001-03	
HOR. SCALE: 1:50 VERTICAL SCALE: 1:50	RELEASED FOR CONSTRUCTION BY: T. KJARTANSON	CONSULTANT DRAWING NO. 66303D-CE1.04		ELECTRICAL FLOOR PLAN POWER	
NO. REVISIONS	DATE BY	DATE 2005/01/05	DATE 2005-02-18		