



## 266-2023 ADDENDUM 1

### SANITARY SEWER SERVICE PIPE REPLACEMENT FOR 880 DALHOUSIE DRIVE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: July 19, 2023  
BY: Steven Goldstine  
TELEPHONE NO. 204 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, July 24, 2023.

#### **PART E – SPECIFICATIONS**

Revise: E6.7.1 to read: The supply and installation of paving stones for indicator surfaces will be considered incidental to surface restorations and will be paid for in accordance with the lump sum price of this Contract.

#### **QUESTIONS AND ANSWERS**

**Q1:** Can HDPE used as an approved alternative to PVC for the trenchless method (directional drilling) sections?

**A1:** HDPR is not approved for this project.

**Q2:** Should there be a Form B for the detailed items of this project?

**A2:** There is no Form B for this project. All work under this project scope shall be covered within the lump sum price of Work submitted in the Bid through MERX.

**Q3:** Is a Bid Bond necessary for this project?

**A3:** A Bid Bond is not necessary for this project.

**Q4:** Is the Contractor required to take out a servicing permit?

**A4:** Yes.

**Q5:** Will the Contractor be required to pay for lane closures?

**A5:** No. The Contract Administrator will arrange for lane closures with the City's Traffic Management Branch.