



640-2023 ADDENDUM 2

SUPPLY AND DELIVERY OF WATER METERS – VARIOUS SIZES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: September 12, 2023
BY: Dennis Kwast
TELEPHONE NO. 431-336-1767

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace 640-2023 Form B: Prices with 640-2023 Addendum 2 - Form B(R1): Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Approximate quantity changed to Items No. 3 & 4.

PART E – SPECIFICATIONS

Add: E2.22 Water meters shall be shipped with inlet and outlet covers to protect the internal components from debris and contamination during transportation. Inlet and outlet caps shall be easily removable at the time of installation without the use of special tools.

PART D – SUPPLEMENTAL CONDITIONS

Revise D10.1.1 to read: Goods shall be delivered within one hundred twenty (120) Business Days of placing an order.