




ORIGINAL SHEET - ISO ARCH D - v17.05





NOTE:

1. CABLE TRAY INSTALLATION SHALL ADHERE TO CEC 12-2200. WHERE PERMITTED BY CODE, CONTRACTOR MAY SUBMIT A REQUEST TO THE OWNER TO REDUCE THE CLEARANCES BETWEEN THE TRAY SECTIONS.



Stantec Architecture Ltd. Suite 500, 311 Portage Avenue Winnipeg MB Canada R3B 2B9 Tel. 204.489.5900 Fax. 204.453.9012 www.stantec.com

Copyright Reserved

The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay. The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Client

Legend

Notes

_____ _____ By Appd. YY.MM.DD Revision _____ ____ ____ _____
 CB
 AA
 23.09.18

 By
 Appd.
 YY.MM.DD
0 ISSUED FOR CONSTRUCTION lssued _____
 CB
 AA
 CB
 22.05.27
File Name: 115423001e_e-304m

Permit-Seal

MANITOBA Certificate of Authorization Stantec Consulting Ltd. No. 1301

Dwn. Chkd. Dsgn. YY.MM.DD

Client/Project

WINNIPEG TRANSIT DIRECT CURRENT FAST CHARGING BUS STATIONS BRANDON GARAGE

600 Brandon Ave. Winnipeg, Manitoba

Title STRUCTURAL DETAILS

Project No. Scale As Indicated 144523001 Drawing No. Sheet E-304 12 _{of} 12

Revision 0