



783-2023 ADDENDUM 7

CONSTRUCTION OF NEW LIGHTING HOUSE BRIDGE & ASSOCIATED WORKS – RAINBOW STAGE – 2015 MAIN STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: January 8, 2024
BY: Lou M. Chubenko
TELEPHONE NO. 204 470-7881

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

Q1: Provide the paint Specifications and Product Data for the primer and paint for all structural and miscellaneous steel fabrications to be installed in the stage area of Rainbow Stage.

A1: Approved Acceptable Products:

System 1 – Alkyd top coats over epoxy primer

Primer: Cloverdale Paint 83110 ClovaMastic Low Temp Cure Epoxy 8311 Series (Colour: Grey).

Top coat 1 & 2: Cloverdale Paint 11147 Marine and Shop Enamel Alkyd (Colour: Flat Black).

System 2 - Alkyd top coats over alkyd primer

Primer: Cloverdale Paint 71016 Rustex Universal Shop Primer Alkyd (Colour: Grey).

Top Coat 1 & 2: Cloverdale Paint 11147 Marine and Shop Enamel Alkyd (Colour: Flat Black)

In accordance with B7 Substitutes, in the case of a request for approval as “an approved alternative”, the substitute will adequately perform the functions called for by the general design, be similar in substance to that specified, is suited to the same use and capable of performing the same functions.