

1024-2024B ADDENDUM 02

7 OAKS POOL RENEWAL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 21, 2025
BY: Tom Berthin (Crosier Kilgour)
TELEPHONE NO. 204 943-7501

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

DRAWINGS

Replace: 1024-2024B _Drawing_S2.5 R0 with 1024-2024B _Addendum_02 Drawing S2.5 R1

NMS SPECIFICATIONS

Section 09 30 13 Ceramic Tiling

Revise: 2.1.5.1 (Ceramic tile (CT-4)) to read: No Diving Symbol. Custom ceramic tile with graphic text as shown on Detail 2 of Drawing A4.0.

Section 10 14 15 Interior Signage

Add: Section 10 14 15 Interior Signage

QUESTIONS AND ANSWERS

Q1: Drawing A1.0 Pool Plan: Tactile Walking with Wayfinder Tiles are drawn, but Tactile Walking Tiles with Domes are specified.

A1: Drawing graphic at tactile locations on A1.0 Pool Plan indicates the location of tactile warnings and not the style of tactile warnings. Refer to NMS Section 09 30 13 – Ceramic Tiling, CT-4 for style of tactile warnings.