



60-2024 ADDENDUM 1

PROFESSIONAL CONSULTING SERVICES FOR SEWPCC & WEWPCC SLUDGE HOLDING TANKS REFURBISHMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 23, 2024
BY: Arash Kiayee, M.Sc., P.Eng.
TELEPHONE NO. (204) 918-1391

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise D10.4 (a) to read: Review performance and sizing of the existing odor control system associated with foul air fan S692-EF (installed in the sludge holding tank room) and truck exhaust fan S694-EF (installed in the sludge truck bay) including the air intake and exhaust lines, the existing thermal oxidizer package system, and oxidizer bypass line discharging to exhaust fan S606-EF. Provide recommendations to modify / upgrade the system to ensure its proper operation. Any modification to the existing thermal oxidizer and/or exhaust fan S606-EF, if required, will be out of the detailed design scope of work.
- Revise D10.7 (a) to read: The report shall include the Scope of Services indicated in D10.

PART E – APPENDICES

- Revise E1.1: Additional photos and drawings regarding the existing odor control system.

Note: The link to access the additional photos and drawings will be emailed to proponents who signed Appendix B - Non-Disclosure Agreement.