



## 415-2025 ADDENDUM 5

### CHLORINE VENTILATION UPGRADES AT REGIONAL PUMPING STATIONS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: July 3<sup>rd</sup>, 2025  
BY: Drew Murray  
TELEPHONE NO. 204 986-2492

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **TENDER TITLE PAGE**

Revise: CHLORINE VENTILATION UPGRADES TO REGIONAL PUMPING STATIONS to read: CHLORINE VENTILATION UPGRADES TO REGIONAL PUMPING STATIONS

#### **PART B – BIDDING PROCEDURES**

Revise: B1.1 to read: CHLORINE VENTILATION UPGRADES TO REGIONAL PUMPING STATIONS

#### **NMS SPECIFICATIONS**

Section 23 33 14 Balancing Damper Specification.

Revise: 2.2.8. to read: Acceptable Materials: Ruskin, Greenheck, equivalent Nailor Industries Damper, or approved equal in accordance with B7.

Section 23 33 15.01 Control Damper Specification.

Revise: 2.1.11. to read: Acceptable materials: Tamco 9000SC, equivalent Alumavent 3900 Series Damper, or approved equal in accordance with B7.

Revise: 2.2.11. to read: Acceptable materials: Fiberglass-reinforced polymer (FRP) Hartzell FCO or FCP Dampers, equivalent Ruskin Damper with viton blade seal and fiberglass axles, or approved equal in accordance with B7.

Section 23 34 00.2 HVAC Fans (Supply Fans Specification).

Revise: 2.6.7. to read: Fans shall be model SQ manufactured by Greenheck, equivalent COOK Fan Corporation SQN-B model, or approved equal in accordance with B7

Section 23 34 00.3 HVAC Fans (Unoccupied Exhaust Fans Specification).

Revise: 2.5.10. to read: Fans shall be model 6-BCSW-FRP-10-I-4 as manufactured by Greenheck Corporation, equivalent COOK Fan Corporation FCP-66 model, or approved equal in accordance with B7

Section 23 41 00 Particulate Air Filtration

Revise: 2.4.6. to read: Acceptable materials: PerfectPleat 4" HC M8, equivalent Camfil filter, or approved equal in accordance with B7.

.